TROX GmbH
Heinrich-Trox-Platz
D-47504 Neukirchen-Vluyn

Telefon +49 (0)2845/202-0
Telefax +49 (0)2845/202-265
e-Mail trox@trox.de

FILTER PRÜFBERICHT NACH ISO 29463-4
FILTER TEST REPORT ACCORDING TO ISO 29463-4

DATUM .....: **07.01.2022**
DATE

PRÜFNUMMER .....: **93820**
TESTNUMBER

PRÜFER .....: **Bruckmann**
INSPECTOR

KOMMISSION .....: **DE1528331**
COMMISSION

POSITION .....: **20**
ITEM NO

RUN/ROLL-NUMMER .....: **422100348226-10.01.**
RUN/ROLL-NUMBER

FILTERDATEN:
DATA OF FILTER

ARTIKELNUMMER .....:
TYPE
MFPCR-H14-ALG/840x510x90x70/PD/RAL9010/0/CSU

ABMESSUNGEN BxHxT.....[mm]: **0840x0510x0090**
DIMENSIONS

FILTERKLASSE NACH EN 1822-1: **H14**
FILTER CLASS ACC. TO EN 1822-1

VOLUMENSTROM .....[m3/h]: **695**
NOMINAL AIR FLOW

DRUCKDIFFERENZ .....[Pa]: **85**
PRESSURE DIFFERENTIAL

ABSCHEIDEGRAD .....[%]: **99,995**
EFFICIENCY

PRÜFDATEN:
DATA OF MEASUREMENT

SCANDAUER .....[s]: **68**
DURATION OF TEST

ROHLUFTKONZENTRATION .[1/m3]: **2,24E+10**
CONCENTRATION UPSTREAM

REINLUFTKONZENTRATION [1/m3]: **8,03E+04**
CONCENTRATION DOWNSTREAM

DRUCKDIFFERENZ .....[Pa]: **85**
PRESSURE DIFFERENTIAL

ABSCHEIDEGRAD .....[%]: **99,995**
EFFICIENCY

FILTER LECKFREI
FILTER CERTIFIED LEAKFREE

FILTERNUMMER : 66823
SERIAL NUMBER